

Display energy certificate (DEC)

Dry Drayton Primary School
Park Street
Dry Drayton
CAMBRIDGE
CB23 8DA

Operational rating

C

Certificate number: 9298-0272-5197-8048-0820

Valid until: 29 November 2033

Total useful floor area: 789.14 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A		
26-50	B		
51-75	C	64 C	
76-100	D		
			100
101-125	E		
126-150	F		
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	30.91	79.87
Typical energy use (kWh/m ² /year)	40	148.61
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
November 2023	64 C
April 2013	96 D

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
November 2023	13	12	0
April 2013	13	22	0

Assessment details

Assessor's name	Michael Robeson
Employer/Trading name	Energy Evaluations & Solutions Ltd.
Employer/Trading address	Hadleigh Business Centre
Assessor's declaration	Not related to the occupier.
Accreditation scheme	Elmhurst Energy Systems Ltd
Issue date	22 November 2023
Nominated date	30 November 2023